



CITY OF SEABROOK

AGENDA BRIEFING

Date of Meeting: 11/15/16

Submitter/Requestor: Arthur Chairez

Date Submitted: 11/04/16

Presenter: Arthur Chairez

Description/Subject: Seabrook 2016 Sanitary Sewer Rehabilitation Project 2016-14

Purpose/Need: Need to repair 6" & 8" sanitary sewer line on back utility easement of Allegro Dr, Beechcraft Street, and Coronado Street by the Cured in Place Pipe (CIPP) lining and pipe bursting methods.

Background/Issue: The sanitary sewer lines are ABS Truss/Concrete Pipes with numerous joints leaking with vertical and horizontal cracks on the pipes.

Impacted Parties: Public Works, BuyBoard and Insituform Technologies, Inc.

Miscellaneous Comments: This project is a continuing effort by the Utility Department to reduce infiltration and leakage into the sanitary sewer system to prevent blockages & overflows. It also adds more capacity, improves operations at the WWTP and the overall infrastructure of the sanitary sewer system.

Recommended Action: Accept proposal from Insituform Technologies Inc. to rehabilitate the 6 & 8 inch sanitary sewer mains on Allegro Dr, Beechcraft Street, and Coronado Street through the BuyBoard.

Attachments: Proposal from Insituform Technologies Inc., Contract and map w/links

Fiscal Impact: Budgeted [X] Yes ___ No Finance Officer Review:
Budget Amendment Required ___ Yes [X] No
Future/Ongoing Impact ___ Yes [X] No
Budget Dept/Line Item Number 912-6100
Approximate Total Amount of Expenditure \$ 101,630.40

Where on the agenda should this item be placed: Bid Awards

Suggested Motion: Approve the proposal from Insituform Technologies Inc. through the BuyBoard in the amount of \$ 101,630.40 to repair 6 inch and 8 inch sewer mains on Allegro Dr, Beechcraft Street, and Coronado Street. This is a budgeted item.